Subtle differences do exist between the test procedures and specifications of these organizations.

To claim ratings to NEMA specifica-

To comply to UL and IEC specifica-tions, the manufacturers must sub-mit product samples, materials used and other data to an independent testing laboratory before ratings can be claimed.

In addition, IEC "IP" ratings differ from NEMA in that they do not apply to protection against the risk of explosion or conditions such as humidity, corrosive gases, fungi or vermin. In addition, different parts of the equipment can have different

degrees of protection and still comply.

The chart shown below is a comparison of the NEMA/UL/EC enclosure specifications to be used as an approximate reference only. Do not use the table to convert from IEC to NEMA designations. For a definition of the ratings listed, see examples below and tables on Page 13-3.

NEMA/UL/IEC Enclosure Type Cross-Reference — Approximate

NEMA Enclo- sure	IP10	IP.20	PZI	ΡZ	PZ3	P30	IP31	ΡΣ	P33	P40	P41	D-42	P43	IP50	PSI	Pg	PS3	PS4	PSE	P36	IP60	P61	P62	IPGS	P64	P66	P66	19d	PGS
Rating	≟	ĕ.	E	Ē.	ĕ.	⊟	ĕ.	⊟	⊟	ĕ	ĕ	ď	≟	ĕ	Ē	≟	ĕ	Ē	Ē	ĕ	ĕ	ĕ	ĕ	ĕ	ĕ	⊒	ĕ	ĕ	⊒
1	Х	Х	Х	Х	Х																								
2	Х	Х	Х	Х	Х						П			П														П	
3	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х				
3R	Х	Х	Х	Х	Х	Х	Х	Х																					
3S	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х				
4	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х		
4X	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х		
6	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	
6P	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х
12	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х			
13	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х	Х			

NOTE: IEC 529 does not specify equivalents to NEMA Enclosure Types 7, 8, 9 or 10.

IEC Environmental Enclosure Ratings — Examples of Designations

	IP	4	4		IP	2	:
Characteristic letters 1st characteristic numeral (See Table 1 Next Page)				Characteristic letters 1st characteristic numeral (See Table 1 Next Page)			
2nd characteristic numeral				2nd characteristic numeral			

An enclosure with this designation is protected against the penetration of solid objects greater than 1.0 mm and against splashing water.

An enclosure with this designation is protected against the penetration of solid objects greater than 12 mm and against splashing water.

13



INCORPORATED

F:T•N Cutler-Hammer

Index of Enclosure Ratings — IEC

Table 1 — 1st Characteristic Numeral

Protected against contact and penetration of solid rotection again st solid objects greater an 50 mm. otection again st solid objects greater an 12 mm. Not protected. Protection against solid objects greater han 1.0 mm.

Table	Table 2 — 2nd Characteristic Numeral							
0	Not protected.							
1	Protection against dripping water.							
2	Protection against dripping water when tilted up to 15 degrees.							
3	Protection against rain.							
4	Protection against splashing water.							
5	Protection against water jets.							
6	Protection against heavy seas.							
7	Protection against the effects of immersion.							
8	Protection against submersion.							

Appendix Enclosure Ratings

NEMA Definitions Pertaining to Non-hazardous Locations NEMA Standard 250

August 2007

Enclosures are intended for indoor use, primarily to provide a degree of protection against contact with the enclosed equipment.

Type 3
Enclosures are intended for outdoor use, primarily to provide a degree of protection against windblown dust, rain, sleet and external ice formation.

Enclosures are intended for outdoor use, primarily to provide a degree of protection against falling rain, sleet and external ice formation.

Type 4

Enclosures are intended for indoor or outdoor use, primarily to provide a degree of protection against windblown dust and rain, splashing water and hose-directed water.

Type 4X Enclosures are intended for indoor or outdoor use, primarily to provide a degree of protection against corrosion, windblown dust and rain, splashing water and hose-directed water.

Type 6

Enclosures are intended for indoor or outdoor use, primarily to provide a degree of protection against the entry of water during occasional temporary submersion at a limited depth.

Type 6P

..
Enclosures are intended for indoor or outdoor use, primarily to provide a degree of protection against the entry of water during prolonged submersion at a limited depth.

Type 12

Enclosures are intended for indoor use, primarily to provide a degree of protection against dust, falling dirt, and dripping non-corrosive liquids.

Enclosures are intended for indoor use, primarily to provide a degree of protection against dust, spraying of water, oil and non-corrosive coolant.

NEC Definitions Pertaining to Hazardous Locations -Article 500

13-3

E51 Limit Switch Type Proximity Switches are rated for use in the fol-lowing locations:

- Class I Division 2, Groups A, B, C or D—Indoor Use

 For the definition of a Class I Division 2 location, see National Electrical Code Article 500-5, paragraph (b).
- For the definitions of Class I Group A, B, C, D Classifications, see the National Electrical Code Article 500-3, paragraph (a).

- Class II Division 2, Groups F or G—
 Indoor Use

 For the definition of a Class II Division 2 location, see National Electrical Code Article 500-6, paragraph (b).
- For the definitions of Class II Group F and G Classifications, se the National Electrical Code Arti-cle 500-3, paragraph (b).

Class III Division 2 — Indoor Use

- For the definition of a Class III
 Division 2 location, see National
 Electrical Code Article 500-7,
 paragraph (b).

 For the definitions of Class III
 Classifications, see the National
 Electrical Code Article 500-7.

PG08301004E

For more information visit: www.eaton.com